

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
British International School
Sector D:-Extension
Sainik Colony Jammu

No. JDF&ES/FP/ 2813

Dated : 28 04.2023

Sub. Provisional Fire Safety Certificate


Ref: Your online Application submission dated 15-09-2022

Sir

The Inspection of above said School was got carried out by the Inspecting officer of this department. During inspection it was found that the Management has installed Sprinklers, Hydrants , Smoke Detectors, Hose Reel Hoses, Fire Pumps and First Aid Fire Extinguishers of different make and capacity in their School premises, besides two underground water storage tanks of 75KL capacities each respectively. The School is 06 Km away from Fire and Emergency Station Gangyal and is approachable for fire tenders in case of any emergency. As such this office has no objection for running the School subject to adopt the following fire safety precautionary measures in letter and spirit-

1. All exists/Staircase should be kept open and free from any obstruction for easy and safe evacuation of inmates during any Emergency.
2. Hose Cabinet should be installed near each Fire Hydrant Point.
3. Fire Pump should be on Automatic Pressurized Mode.
4. First Aid Fire Fighting System installed in the School building should be checked periodically. Staff and Students should be fully trained in handling/operating of Fire Fighting system installed in the School building .The management shall intimate this office in writing after each quarter that the Fire fighting equipments installed in the School are functioning
5. **No Hazardous material should be kept inside or outside of the School premises (especially LPG Cylinder, Petrol and Diesel etc.)Any deviation found in this regard the clearance will be treated withdrawn/cancelled**
6. All Class rooms and Examination Halls having Seating Capacity for more than 45 students need to be provided with two exits
7. One Window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
8. The Corridor of building shall not be used for any kind of Storage.
9. The Management shall be wholly and solely responsible for keeping the fire fighting system in working condition 24*7 and safe evacuation of its students during any mishap.
10. Telephone numbers of nearest Fire & Emergency Stations should be displayed
11. At present School is having two triple storied concrete buildings. As such no addition/alteration should be made by the School management in the existing Structure without prior permission from the department .Any deviation found in this regard; this clearance will be treated withdrawn/cancelled.
12. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the School.

Yours Sincerely


Joint Director
Fire & Emergency Services
Jammu Range, Jammu



28/4/23